


कार्यालय नगर निगम, देहरादून।




(का0-0135-271407:फैक्स-0135-2651060:ई-मेल-nagarnigam.ddun@gmail.com)

पत्रांक: 763 CH)

दिनांक: 11/11/22

अनापत्ति प्रमाण-पत्र

प्रमाणित किया जाता है कि "श्री गुरु राम राय पब्लिक स्कूल" स्थित तालाब, देहरादून में पीने के पानी एवं टॉयलेट/यूरिनल/बाथरूम का सफाई सम्बन्धित निरीक्षण दिनांक 07.11.2022 को किया गया। स्कूल में स्वच्छता/साफ-सफाई (हेल्थ/हाइजिन) व्यवस्था सही पायी गयी। स्वच्छता/साफ-सफाई सम्बन्धित कोई आपत्ति नहीं है तथा सफाई सम्बन्धित अनापत्ति प्रमाण पत्र जारी किया जाता है, जिसकी वैधता आगामी 01 वर्ष (2022-2023) तक मान्य होगी।



मुख्य नगर स्वास्थ्य अधिकारी,
नगर निगम, देहरादून।



Principal

S.G.R.R. Public School

Talab, Dehra Dun



Authorised Signatory
& Manager

SGRR EDUCATION MISSION, DEHRADUN



Test Report ID: 179/UJS/SLWQTML/2022-23

URL No.: TC53722200000000179F

Dated: 30/09/2022

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School, Talab, Dehradun		
Product Description	Drinking Water	Sample Description	One Water Sample Collected From Shri Guru Ram Rai Public School, Talab, Dehradun
Reference Sample Identification:	SLWQTML/UJS/SG-01		Date of Start of Analysis: 27/09/2022 Date of End of Analysis: 30/09/2022
Date and Time of Sample Received: 27/09/22 & 11:30PM	Sample Collected by:	Customer:	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.13	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA. 2017 Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	98	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	Less than 01	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	82	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	22	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Fluoride, mg/L, Max	Less than 0.1	1.0	1.5	APHA 23rd Ed. 4500-F-D: 2017: SPADNS Method
7.	Nitrate, mg/L, Max	Less than 01	45	No Relaxation	APHA 23rd Ed. 4500-NO ₃ -B:2017: Ultraviolet Spectrophotometric Screening Method
8.	Sulfate, mg/L, Max	07	200	400	APHA 23rd Ed. 4500-SO ₄ ²⁻ E:2017 Turbidimetric Method
9.	Chloride, mg/L, Max	2.9	250	1000	IS 3025 (Part 32): 1988, RA. 2019 Argentometric Method
10.	Colour, Hazen, Max	Less than 01	5	15	IS 3025 (Part 4): 2021 Platinum Cobalt (Visual Comparison)
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8) : 1984, RA:2017
12.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018

Remark: Above received water sample conform to IS 10500:2012 for drinking purpose with respect to above test parameters.

Rawal
Principal
S.G.R.R. Public School
Talab, Dehra Dun

V Rawal
Authorised Signatory
of Manager
Uttarakhand Jal Sansthan
Dehradun
(Dr. Wilash Khandari)

-End of Report

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



Test Report ID: 179A/UJS/SLWQTML/2022-23

Dated: 30/09/2022

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Ram Rai Public School Talab, Dehradun		
Product Description	Drinking Water	Sample Description	One Water Sample Collected From Shri Guru Ram Rai Public School, Talab, Dehradun
Reference Sample Identification:	SLWQTML/UJS/SG-01		Date of Start of Analysis: 27/09/2022 Date of End of Analysis: 30/09/2022
Date and Time of Sample Received: 27/09/22 & 11:30PM	Sample Collected by:		Customer:

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	Residual Free Chlorine, mg/L, Min	Not Detected	0.2	1.0	APHA 23rd Ed.-4500-Cl-G
2.	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
3.	E. coli, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B

Remark: Above received water sample conform to IS 10500:2012 for drinking purpose with respect to above test parameters.

Vikash Kandari
30/9/22

(Dr. Vikash Kandari)

Authorised Signatory
SLWQTM, Lab
Uttarakhand Jal Sansthan
Dehradun

Qavite
Principal
S.G.R.R. Public School
Talab Dehra Dun

V Rawal
Authorised Signatory
of Manager
SGRR EDUCATION MISSION, DEHRADUN

-End of Report -

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.